

Water/Wastewater Report

Water Department Report

The water department produced 2,328,900 gallons of water, for a daily average of just over 75,000 gallons. Dead end main flushing was just short of 10,000 gallons. Flushing is required by the TCEQ of all "dead end" mains.

For the month of June by comparison we produced 2,471,000 gallons of water, for an average of 82,000 gallons. June we

flushed just over 12,300 gallons.

On July 25th the packing ring retainer broke on the South Well, making this well inoperative. Service was called and a new part is on order. This well is the smallest of the three and will be put back in service ASAP.

Tandem Tank and Tower made our required annual water tower and ground

storage inspection with the following notes:

Water Tower: interior is in good condition, exterior is in fair condition, may need over coating in 2-5 years. North Well interior, exterior in good condition. Exterior was washed the next day. East well both interior and exterior in good condition.

The DLQOR/STEERS reports we completed for the second quarter 2017

Special points of interest:

- The month of July we had 3.8 inches of rain.
- WWTP treats approximately 52 thousand gallons of waste every day.
- An estimated 49,000 gallons of water were lost due to leaks this month.

Wastewater Department Report

The Wastewater department treated 1.63 million gallons for the month of July. This month's DMR reported two flow violations that exceeded the limit of .08 MGD.

On July 25th we completed WWTP final walk thru with TWDB and SPI. No items needed to be corrected.

Identified two places of Inflow and Infiltration. One was an abandoned collection line on Annie

Street that was capped. A man hole Located next to hiway 69 was identified as defective and a new manhole is ordered.

Local resident called reported that sewer water was flowing out of the storm drain on Quitman St. The collection system was backed up and we unstopped it within the hour. Returning the next to replace approximately 45 feet of sewer main. This unauthorized

discharge required immediate notification to TCEQ.

Replaced broken sewer tap at 519 Quitman St.

Installed a 22 foot culvert on Mockingbird Street.

Street repairs to start as soon as we can get the rolling machine from Lennon Construction.



Follow up