



Water/Wastewater Report

Water Department Report

The water department produced 2,074,322 gallons of water, for a daily average of 66,913 gallons in the month of October.

For the month of September by comparison, produced 3,479,749 gallons of water, for an average of 112,250 gallons per day.

Flushing of the dead end mains used 10,160 gallons of water.

We had 1 new water tap on FM 17 North.

East well tripped for over voltage. Now back in service.

We had 2 leaks this month est. 50K lost.

Completed new swing set at City Park.

Relocated water line out from under house on CR1689.

Wastewater Department Report

The Wastewater department treated 1.79 million gallons for the month October.

This month's DMR should reflect 2 flow violations.

Patched streets.

Customer sewer blockage unstopped 1 place.

Mowing, weed eating and shredding has continued.

Cleaned sludge drying bed.

TxDot permit approved for new sewer tap in FM17. Met with Property owner and gave him the new quote for install.

Contacted owner at Y'all Come Café about sewer issues on rental property.

Repaired drain in Police Dept.

Paul out for surgery.